





Utility Conflict Report

OWNER	Utility	CPS	Corridor	RIGSBY	SITE PHOTOS	
	Contact	BILL FEY	ID	2063		
GENERAL INFO	Utility	GAS				
	Size and Material	STANDARD GAS VALVE, CAST IRON				
	Utility Conflict Description	GAS VALVE WITHIN PROPOSED SIDEWALK				
	Longitudinal or Crossing	LONGITUDINAL				
	Placement Relative to ROW	INSIDE				
LOCATION	Sheet No.	240				
	Station Origin					
	Start Station	119+24.70	End Station			
	Start Offset	9.6	End Offset			
	Latitude	29.397974246	Longitude	-98.437274152000001		
SUE	Level of Investigation Req'd	NONE				
	Test Hole No	N/A				
	Test Hole Depth	N/A				
RESOLUTION	Recommended Action	MINIMIZE - PROTECT IN PLACE				
	Estimated Resolution Date					
	Resolution Status	UTILITY COORDINATION IN PROGRESS				
	Comment	ADJUST GAS VALVE LIDS (3) TO PROPOSED GRADE DURING CONSTRUCTION (4-6", 4-6", AND 1-3" VERTICAL LOWERING ANTICIPATED RESPECTIVELY). GAS VALVE ADJACENT TO DRIVEWAY HAS 1.2" CLEARANCE BETWEEN THE VALVE AND LID. VALVE NEEDS TO BE LOWERED.				
Date Collected		8/14/2017 9:37:08 AM		Date Modified	11/30/2017 9:01:41 AM	

TBPE Firm Registration #470 | TBPLS Firm Registration #10028800