

Utility Conflict Report

OWNER	Utility	CPS	Corridor	RIGSBY	SITE PHOTOS	
	Contact	BILL FEY	ID	224		
GENERAL INFO	Utility	GAS				
	Size and Material	STANDARD GAS VALVE, CAST IRON				
	Utility Conflict Description	GAS VALVE WITHIN PROPOSED DRIVEWAY, INSIDE ACCESSIBLE ROUTE				
	Longitudinal or Crossing	CROSSING				
	Placement Relative to ROW	INSIDE				
LOCATION	Sheet No.	319				
	Station Origin					
	Start Station	636+52.95	End Station			
	Start Offset	11.4	End Offset			
	Latitude	29.398372097	Longitude	-98.428219522999996		
SUE	Level of Investigation Req'd	NONE				
	Test Hole No	N/A				
	Test Hole Depth	N/A				
RESOLUTION	Recommended Action	MINIMIZE - PROTECT IN PLACE				
	Estimated Resolution Date					
	Resolution Status	UTILITY COORDINATION IN PROGRESS				
	Comment	ADJUST GAS VALVE LIDS (2) TO PROPOSED GRADE DURING CONSTRUCTION (<1" VERTICAL CHANGE ANTICIPATED)				
Date Collected		9/20/2017 6:49:12 PM		Date Modified 11/9/2017 5:45:01 PM		

