

Utility Conflict Report

OWNER	Utility	SAWS	Corridor	HOUSTON	SITE PHOTOS
	Contact	NINA BITTLE	ID	245	
GENERAL INFO	Utility	WATER			
	Size and Material	STANDARD WATER METER, STEEL			
	Utility Conflict Description	WATER METER WITHIN PROPOSED DRIVEWAY, OUTSIDE ACCESSIBLE ROUTE			
	Longitudinal or Crossing	CROSSING			
	Placement Relative to ROW	INSIDE			
LOCATION	Sheet No.	135			
	Station Origin				
	Start Station	303+70.88	End Station		
	Start Offset	29.38	End Offset		
	Latitude	29.423880193	Longitude	-98.404392223000002	
SUE	Level of Investigation Req'd	NONE			
	Test Hole No	N/A			
	Test Hole Depth	N/A			
RESOLUTION	Recommended Action	MINIMIZE - PROTECT IN PLACE			
	Estimated Resolution Date				
	Resolution Status	UTILITY CONFLICT RESOLVED			
	Comment	ADJUST WATER METER LID TO PROPOSED GRADE DURING CONSTRUCTION (4-6" VERTICAL LOWERING ANTICIPATED)			
Date Collected		11/10/2017 11:42:39 AM		Date Modified	8/17/2018 2:20:26 PM

