

## Utility Conflict Report

<b>OWNER</b>	<b>Utility</b>	SAWS	<b>Corridor</b>	BANDERA	<b>SITE PHOTOS</b>
	<b>Contact</b>	ANN PECHE	<b>ID</b>	3223	
<b>GENERAL INFO</b>	<b>Utility</b>	WATER			
	<b>Size and Material</b>	STANDARD WATER VALVE, CAST IRON			
	<b>Accessible Route</b>	ASSET IS OUTSIDE ACCESSIBLE ROUTE			
	<b>Longitudinal or Crossing</b>	CROSSING			
	<b>Placement Relative to ROW</b>	INSIDE ROW			
<b>LOCATION</b>	<b>Sheet No.</b>				
	<b>Station</b>				
	<b>Offset</b>				
	<b>Latitude</b>	+29.496167			
	<b>Longitude</b>	-98.62021			
<b>SUE</b>	<b>Level of Investigation Req'd</b>	NONE			
	<b>Test Hole No</b>	N/A			
	<b>Test Hole Depth</b>	N/A			
<b>RESOLUTION</b>	<b>Recommended Action</b>	NO CONFLICT			
	<b>Estimated Resolution Date</b>	9/13/2018			
	<b>Resolution Status</b>	NO RESOLUTION WAS REQUIRED			
	<b>Comment</b>	Unable to open lid			
<b>Date Collected</b>		8/20/2018 8:20:41 AM		<b>Date Modified</b> 11/28/2018 6:59:12 AM	

