

## **Utility Conflict Report**

ER	Utility	SAWS		Corridor	NOGALITOS	S	SITE PHOTOS		
OWNER	Contact	ANN PECH	E <b>ID</b>	4025					
GENERAL INFO	Utility		WATER						
	Size and Material		STANDARD WATER VALVE, CAST IRON						
	Accessible Route		ASSET IS INSIDE ACCESSIBLE ROUTE						
	Longitudinal or Crossing		CROSSING						
	Placement Relative to ROW		INSIDE ROW						
LOCATION	Sheet No. 113								
	Station 1	11+87.34							
	Offset 2	7.52							
	Latitude +	29.388717							
	Longitude -	<b>.ongitude</b> -98.52194							
SUE	Level of Investigation Req'd		NONE						
	Test Hole No		N/A						
	Test Hole Depth		N/A						
RESOLUTION	Recommended Action		MINIMIZE - PROTECT IN PLACE						
	Estimated Resolution Date								
	Resolution Status		UTILITY OWNER INFORMED OF UTILITY			LITY			
	Comment		Top of valve to surface = 2.8" Lid thickness = 3/8" Back of curb to valve = 3'4" Lower underlying asset, not enough vertical clearance inside valve box to lower 3-4" needed			-3			
<b>Date Collected</b> 7/2/2018 1:55:22 PM <b>Date Modified</b> 10/12/2018 3:14:06 PM									

TBPE Firm Registration #470 I TBPLS Firm Registration #10028800