

Utility Conflict Report

OWNER	Utility	SAWS	Corridor	NOGALITOS	SITE PHOTOS
	Contact	NINA BITTLE	ID	3077	
GENERAL INFO	Utility	WATER			
	Size and Material	STANDARD WATER VALVE, CAST IRON			
	Accessible Route	ASSET IS INSIDE ACCESSIBLE ROUTE			
	Longitudinal or Crossing	CROSSING			
	Placement Relative to ROW	INSIDE ROW			
LOCATION	Sheet No.				
	Station	141+56.40			
	Offset	31.1081			
	Latitude	+29.395238			
	Longitude	-98.51616			
SUE	Level of Investigation Req'd	NONE			
	Test Hole No	N/A			
	Test Hole Depth	N/A			
RESOLUTION	Recommended Action	NO CONFLICT			
	Estimated Resolution Date	8/13/2018			
	Resolution Status	NO RESOLUTION WAS REQUIRED			
	Comment	Top of valve to surface = 4'-5" Lid thickness = 5" Sidewalk width = 7'-0" Valve to face of wall = 5'-5 1/2"			
	Date Collected		7/11/2018 2:58:33 PM	Date Modified	

