


GENERAL NOTES



1. All materials and construction procedures within the scope of this contract shall be approved by the San Antonio Water System (SAWS) and comply with the following as applicable:

A. Current Texas Commission on Environmental Quality Design Criteria for Sewerage Systems [31 TAC 217.1, 31 TAC 217.2, 31 TAC 217.3, and 31 TAC 217.13 and 213].

B. Current TXDOT "Standard Specifications for Construction of Highways, Streets and Drainage."

C. Current "San Antonio Water System Standard Specifications for Construction."

D. Current City of San Antonio "Standard Specifications for Public Works Construction."

E. Current Bexar County Specifications.

F. Current City of San Antonio "Right - of - Way Management and Criteria Manual".

2. The Contractor/Foreman is to notify and make arrangements with the SAWS Construction Inspector Division at 233-3500 and involve the home resident and/or property owners 48 hours prior to excavation.

3. The existence and location of underground utilities indicated on the plans are taken from the best records available and are not guaranteed to be accurate. The Contractor/Foreman is responsible for maintaining, supporting, and protecting the integrity of underground utilities and power poles during construction, and is required to call the following numbers 48 hours before beginning any excavation.

San Antonio Water System	233-2010
Storm Water Engineering	207-5009
COSA Traffic Signal Operations	207-7720
Texas State Wide One Call Locator	1-800-545-6005
Bexar Metropolitan Water District	354-6536



4. If damaged, the Contractor/Foreman shall be responsible for restoring existing fences, curbs, streets, driveways, sidewalks, landscaping, structures, etc. to its original or better condition. (No Separate Pay Item)

5. Trench excavation protection shall be accomplished as required by the provisions of Part 1926, Support P-Excavation, Trenching, and Shoring of The Occupational Safety and Health's Standards and Interpretations. The Contractor shall also comply with the provisions included in Item 550, Trench Excavation Safety Protection, of the current San Antonio Water System Specifications for Water and Sanitary Sewer Construction.

6. The Contractor/Foreman shall avoid cutting roots larger than one inch in diameter when excavating near existing trees. Excavation in vicinity of trees shall proceed with caution. The Contractor/Foreman shall contact the City Arborist at 207-8053 for guidance.

SEE SHT. 2 OF 3 & 3 OF 3
FOR LOCATION MAPS

LOCATION MAP
N.T.S.



768

STATE OF TEXAS
SANDRA L. GOMEZ
98284
LICENSED PROFESSIONAL ENGINEER
Sandra L. Gomez
4/28/11

No televising report was submitted for this portion of project

JOB NO. 11-4501		
2011 REHABILITATION WORK		
ORDER CONSTRUCTION		
CONTRACT - W.O. #17		
Central City Rehab Project		
<small>DR: A.F.D. CR: S.L.G. CK: S.L.G.</small>	<small>SAN ANTONIO WATER SYSTEM</small>	<small>DATE</small> Mar. 18, 2011
<small>BLK. MAP:</small> 162-576 160-578	<small>REPLACEMENT & IMPROVEMENTS</small>	<small>SHEET</small> 3 OF 3